

C. DUKES SCOTT  
EXECUTIVE DIRECTOR

1401 Main Street, Suite 900  
Columbia, SC 29201



DAN E. ARNETT  
CHIEF OF STAFF

Phone: (803) 737-0800  
Fax: (803) 737-0801

shudson@regstaff.sc.gov

*Shannon Bowyer Hudson  
Counsel for ORS*

March 15, 2009

**VIA ELECTRONIC FILING**

Jocelyn Boyd, Esquire  
Interim Chief Clerk & Administrator  
Public Service Commission of South Carolina  
101 Executive Center Drive  
Columbia, South Carolina 29210

Re: Request for Investigation to Determine Whether a Regulation Should Be Promulgated  
Requiring Relocation of Certain Meter Sets or Installation of Splash Guards on These Meter  
Sets - **Docket No. 2005-270-G**  
**Sixth and Final Supplemental Operator Responses**

Dear Ms. Boyd:

On the enclosed table, please find the sixth and final semi-annual compilation of responses provided by jurisdictional Gas System Operators ("operators") in South Carolina pursuant to the Public Service Commission of South Carolina ("Commission") Orders<sup>1</sup> issued in Docket No. 2005-270-G and specifically Order No. 2007-589. All operators report having completed remediation, and unless otherwise ordered by the Commission, this will be the final response.

Respectfully submitted,

Shannon Bowyer Hudson

**Enclosures**

cc: Maureen O. Floyd, Esquire  
James H. Jeffries IV, Esquire  
K. Chad Burgess, Esquire  
Mitchell M. Willoughby, Esquire  
Paul W. Dillingham, Esquire

---

<sup>1</sup> Orders No. 2007-589, 2007-475, 2006-310, 2006-168, and 2006-168(A).

**SIXTH SUPPLEMENTAL OPERATOR RESPONSES  
MARCH, 2010  
PSC Docket No. 2005-270-G**

OPERATORS THAT HAD NOT COMPLETED TYPE 12 METER SET REMEDIATION AS OF 9/09	Date of Supplemental Reply	1. Type 12 Meter Sets on System	2. Type 12 Meter Sets Subject to Service Regulatory Vent Moisture Intrusion and Freezing	3. Remaining Number to be Reconfigured*	4. Remaining Meters to have Splash Guards Installed*	5. Reconfiguration Schedule	6. Splash Guard Installation Schedule	7. Number Reconfigured to Date	8. Number of Splash Guards Installed to Date	9. Forecast for Completing Reconfigurations	10. Forecast for Completing Splash Guard Installations	Comments
Lancaster Co. NGA	3/9/10	* 11,950	** 2422	Complete	Complete	See Comments	Complete	920	1,502	Completed December 2009	Completed December 2009	LCNGA has completed inspection and review of the type 12 meter sets in the system. All known meter sets of this type have been addressed. All meters were visually inspected during calendar year 2009. However, it is possible that some may be discovered in the future. If so, they will be addressed and remediated according to the procedures established and followed by LCNGA regarding the type 12 meter set configuration.

\*1. This number has been revised by LCNGA from 12,000 to 11,950 to reflect the actual number of meter sets that are not affected by vent moisture intrusion and freezing at this time.

\*\*2. This number has been revised after LCNGA's survey of the system to reflect the actual numbers of type 12 meter sets observed and remediated according to LCNGA procedures.